

AIR SAMPLE TESTS for ASBESTOS in MASONRY BUILDINGS

March 2016

OSHA Permissible level of asbestos exposure: 0.1 fiber/cubic centimeter (cc) of air

Location of air sample test		fibers/cc
9E Ridge	1st floor	0.007
9A-F Ridge	crawlspace	0.008
21G Ridge	1st floor	0.017
21A-H Ridge	crawlspace	0.006
11G Ridge	1st floor	0.023
11A-H Ridge	crawlspace	0.007
26F Ridge	1st floor	0.007
26A-F Ridge	crawlspace	0.01
2C Gardenway	1st floor	0.029
2A-F Gardenway	crawlspace	0.007
35G Ridge	1st floor	0.006
35A-G Ridge	crawlspace	0.006
35K Ridge	1st floor	0.007
35H-L Ridge	crawlspace	0.005
58A-D Crescent	crawlspace	<.005*
1B Eastway	1st floor	0.008
1A-D Eastway	crawlspace	<.005*
10B Hillside	1st floor	<.005*
10A-D Hillside	crawlspace	0.006

* less than the Reporting Limit

Please note that the test results show **all types of fibers**, which may or may not contain asbestos.